



Lemoyne Municipal Authority Wastewater Report

April 7, 2022

Dear Council / Authority Members:

- Reporting Month: **February 2022**
- Effluent violations: **No**
- Monthly EDMR submittal date: **March 21, 2022**
- Quarterly EDMR submittal date: **February 22, 2021**
- Annual EDMR submittal date: **November 17, 2021**
(Electronic Discharge Monitoring Report)

February 2022 Data Summary

<u>Parameter</u>	<u>Max</u>	<u>Min</u>	<u>Average</u>	<u>Permit Limit</u>
Flow (Gal.)	532,000	269,000	339,000	n/a
CBOD5 (mg/l)	<2.0	<2.0	<2.0	25 avg 50 max
TSS (mg/l)	6.0	<4.0	<4.4	30 avg 60 max
Phosphorus (mg/l)	0.51	0.24	0.35	4.0 instant 2.0 avg
Ammonia (mg/l)	<0.1	<0.1	<0.1	Monitor & Report
Fecal Coliform (cfu)	1200	6	53	2,000 (geo mean) 10,000 max
Total Residual Chlorine (mg/l)	0.34	0.16	0.24	0.5 avg 1.6 max
pH (S.U.)	7.84	6.91	n/a	6 to 9
Dissolved Oxygen (mg/l)	11.61	10.47	11.0	>5.0

- CBOD5- (Carbonaceous Biological Oxygen Demand)
- TSS- (Total Suspended Solids)

Biosolids

<u># of Loads</u>	<u>Wet Tons</u>	<u>Dry Tons</u>	<u>% Solids Range</u>
<u>1</u>	<u>14.69</u>	<u>2.73</u>	<u>18.6</u>

PA 1 Calls

<u>Routine PA 1 Calls</u>	<u>Emergency PA 1 Calls</u>
<u>35</u>	<u>7</u>

Routine Maintenance / Events

- Biosolids being hauled as generated to Cumberland County Landfill.
- Process control adjustments as required.
- Sampling and Lab Analysis.
- Daily operations ongoing including inspections, cleaning, testing and chemical replenishment.
- Ongoing completion of preventative maintenance schedule.
- Continue to implement NPDES (National Pollution Discharge Elimination System) permit.

Non-Routine Maintenance / Events

- Plant equipment maintenance.
- Monitoring changes made to control nutrient removal.
- Semi-Annual calibrations completed by Control Systems 21 on 11/2/21.
- Annual Form 43 completed on 4/13/21. Biosolids testing for Cumberland County Landfill.
- Working with RETTEW on UV System Design.
- Annual WETT test done.
- Testing for NPDES renewal done.

Collection System

- Ongoing preventative maintenance on trouble spots. (solids, grit, grease, problem areas)
- Working on yearly routine flushing.

WWTP Personnel Info, Classes, Accomplishments

- 2 of 4 plant personnel are Licensed Operators.
- All plant personnel attended PA 1 Call training on 4/21/21.
- PA 1 Call recognized Lemoyne WWTP personnel on having a 100% response rate.
- Bob Oakes took a Valves- Operation and Maintenance class worth 15 hours towards licenses.
- All plant personnel reviewed our EAP (Emergency Action Plan), and our SPCC/PPC (Spill Prevention, Control & Countermeasures / Preparedness, Prevention & Contingency) plan.
- Plant personnel attended Groundskeeping & Landscaping Safety on 3/24/22.

Pending Issues

- Grit system not functioning properly due to being oversized. Not enough flow or velocity to work correctly.
- Digester diffusers continue to clog. Would like to replace with a non-clog diffuser like Relia Ball or similar.
- Second stage oxic tanks are not getting the amount of mixing needed since lowering the amount of air to the tanks to meet our nutrient requirements.

If you have any questions, require more information, or wish to comment on the above information, please feel free to contact me.

Respectfully,

Robert Oakes
Wastewater Superintendent