



## Lemoyne Municipal Authority Wastewater Report

September 2, 2021

Dear Council / Authority Members:

- Reporting Month: **July 2021**
- Effluent violations: **No**
- Monthly EDMR submittal date: **August 20, 2021**
- Quarterly EDMR submittal date: **August 20, 2021**
- Annual EDMR submittal date: **January 4, 2021**  
(Electronic Discharge Monitoring Report)

### June 2021 Data Summary

<u>Parameter</u>	<u>Max</u>	<u>Min</u>	<u>Average</u>	<u>Permit Limit</u>
Flow (Gal.)	391,000	193,000	308,000	n/a
BOD (mg/l)	2.2	<2.0	<2.0	25 avg 50 max
TSS (mg/l)	9.6	<4.0	<5.5	30 avg 60 max
Phosphorus (mg/l)	1.02	0.32	0.73	4.0 instant 2.0 avg
Ammonia (mg/l)	<0.1	<0.1	<0.1	Monitor & Report
Fecal Coliform (cfu)	59	3	11	200 (geo mean) 1,000 max
Total Residual Chlorine (mg/l)	0.42	0.05	0.26	0.5 avg 1.6 max
pH (S.U.)	7.95	6.59	n/a	6 to 9
Dissolved Oxygen (mg/l)	9.12	8.52	8.82	>5.0

- BOD- (Biological Oxygen Demand)
- TSS- (Total Suspended Solids)

### Biosolids

<u># of Loads</u>	<u>Wet Tons</u>	<u>Dry Tons</u>	<u>% Solids Range</u>
<u>3</u>	<u>44.58</u>	<u>9.36</u>	<u>20.7-21.2</u>

### PA 1 Calls

<u>Routine PA 1 Calls</u>	<u>Emergency PA 1 Calls</u>
<u>37</u>	<u>4</u>

### **Routine Maintenance / Events**

- Biosolids being hauled as generated to Cumberland County Landfill.
- Process control adjustments as required.
- Sampling and Lab Analysis.
- Daily operations ongoing including inspections, cleaning, testing and chemical replenishment.
- Ongoing completion of preventative maintenance schedule.
- Continue to implement NPDES (National Pollution Discharge Elimination System) permit.

### **Non-Routine Maintenance / Events**

- Working with Mike Knouse on CIP information.
- Plant equipment maintenance.
- Monitoring changes made to control nutrient removal.
- Semi-Annual calibrations completed by Control Systems 21 on 4/21/21.
- Annual Form 43 completed on 4/13/21. Biosolids testing for Cumberland County Landfill.

### **Collection System**

- Ongoing preventative maintenance on trouble spots. (solids, grit, grease, problem areas)
- Working on yearly routine flushing. Around 25,000 feet cleaned so far.

### **WWTP Personnel Info, Classes, Accomplishments**

- Kyle Janny passed his CDL road test on 7/29/2021.
- Kyle Janny attending HACC Wastewater Operator class.
- All plant personnel attended PA 1 Call training on 4/21/21.
- PA 1 Call recognized Lemoyne WWTP personnel on having a 100% response rate.
- Bob Oakes took a Valves- Operation and Maintenance class worth 15 hours towards licenses.
- All plant personnel reviewed our EAP (Emergency Action Plan), and our SPCC/PPC (Spill Prevention, Control & Countermeasures / Preparedness, Prevention & Contingency) plan.
- Tyler Burgard started employment 7/26/21 at the plant.

### **Pending Issues**

- Grit system not functioning properly due to being oversized. Not enough flow or velocity to work correctly.
- Digester diffusers continue to clog. Would like to replace with a non-clog diffuser like Relia Ball or similar.
- Second stage oxic tanks are not getting the amount of mixing needed since lowering the amount of air to the tanks to meet our nutrient requirements.

If you have any questions, require more information, or wish to comment on the above information, please feel free to contact me.

Respectfully,

Robert Oakes  
Wastewater Superintendent